

(b) (6)

Denise

Please copy +
mail these to
neighbors - regular
mail

Tx!

Both

Note: lab sheet, attach 1 that
matches that household



March 23, 2011

Dear Neighbor:

Thank you for allowing us to sample your drinking water in your home. Attached are your test results for nitrates. The EPA drinking water standard limit for nitrate is 10 mg/l. As you can see, the nitrate level in your water is significantly lower than 10 mg/l. This confirms that your water treatment system is in good working order.

I can be reached at 934-3094, should you have any questions. Thank you for your participation.

Sincerely,

A handwritten signature in cursive script that reads "Beth Sise".

Beth Sise
Environmental Manger

cc: John Wren (Mountaire) gn
Jim Nilan (Mountaire)



Mountaire Farms of Delaware, Inc.
P.O. Box 1320, Millsboro, Delaware 19966
(302) 934-1100 Toll Free (877) 887-1490

"We measure quality by how well we service our internal and external customers"



51 Clark St. Harrington, DE 19952

PH: 302.398.4313 FX: 302.398.4312

ANALYTICAL SERVICES: NPDES, RCRA, GROUND WATER MONITORING

ANALYTICAL RESULTS

Mountaire Farms of Delaware, Inc. [Millsboro]

P.O. Box 1320

Millsboro, DE 19966

Attention: Jim Nilan

Lab ID: 104670

Matrix: Drinking Water

Sample Start: 3/1/11 9:30

Description:

Site: (b) (6)

Sample End:

Type: Grab


(b) (6)

Date Received: 3/2/11 14:15

Parameter	Units	Result	Analyzed	By	Method
Nutrient					
Nitrate as N	mg/L	1.25	3/2/11 21:18	HJG	EPA 300.0

Shelly Burr

ND = Not Detected
* = Above Specified Limit
** = Above Client Limit



51 Clark St. Harrington, DE 19952
PH: 302.398.4313 FX: 302.398.4312

ANALYTICAL SERVICES: NPDES, RCRA, GROUND WATER MONITORING

ANALYTICAL RESULTS

Mountaire Farms of Delaware, Inc. [Millsboro]
P.O. Box 1320
Millsboro, DE 19966
Attention: Jim Nilan

Lab ID: 104400

Matrix: Drinking Water

Sample Start: 2/25/11 13:15

Description:

Site:

(b) (6)

Sample End:

Type: Grab

Date Received: 2/26/11 11:50

Parameters	Units	Results	Analyzed	By	Method
Nutrient					
Nitrate as N	mg/L	<0.4	2/26/11 16:29	HJG	EPA 300.0
Standards & Surrogates					
Nitrate as N (% Recovery)	% Rec.	100.70	2/26/11 16:29	HJG	EPA 300.0

ND = Not Detected
* = Above Specified Limit
** = Above Client Limit



51 Clark St. Harrington, DE 19952

PH: 302.398.4313 FX: 302.398.4312

ANALYTICAL SERVICES: NPDES, RCRA, GROUND WATER MONITORING

ANALYTICAL RESULTS

Mountaire Farms of Delaware, Inc. [Millsboro]

P.O. Box 1320

Millsboro, DE 19966

Attention: Jim Nilan

Lab ID: 104398

Matrix: Drinking Water

Sample Start: 2/25/11 13:15

Description:

Site:

(b) (6)

Sample End:

Type: Grab

Date Received: 2/26/11 11:50

Parameters	Units	Results	Analyzed	By	Method
Nutrient					
Nitrate as N	mg/L	0.63	2/26/11 16:29	HJG	EPA 300.0

ND = Not Detected
* = Above Specified Limit
** = Above Client Limit



51 Clark St. Harrington, DE 19952
PH: 302.398.4313 FX: 302.398.4312
ANALYTICAL SERVICES: NPDES, RCRA, GROUND WATER MONITORING

ANALYTICAL RESULTS

Mountaire Farms of Delaware, Inc. [Millsboro]
P.O. Box 1320
Millsboro, DE 19966
Attention: Jim Nilan

Lab ID: 104399

Matrix: Drinking Water

Sample Start: 2/25/11 13:15

Description:

Site: (b) (6)

SampleEnd:

Type: Grab

Date Received: 2/26/11 11:50

Parameters	Units	Results	Analyzed	By	Method
Nutrient					
Nitrate as N	mg/L	1.54	2/26/11 16:39	HJG	EPA 300.0

ND = Not Detected
* = Above Specified Limit
** = Above Client Limit